

Certificate of Analysis

Report Date: 10/30/15 12:09
Received Date: 10/14/15 15:00

Client: PristineHydro Development Inc.
24102 El Toro Road, Suite D
Laguna Woods, CA 92637

Turnaround Time: Normal

Phone: (949) 581-9191

Attn: Ginger Caulkins

Fax: (949) 581-9192

Project: Annual/Renewal

P.O.#:

Dear Ginger Caulkins :

Enclosed are the results of analyses for samples received 10/14/2015 with the Chain of Custody document. The samples were received in good condition, at 5.3 °C and on ice. All analysis met the method criteria except as noted below or in the report with data qualifiers.

Table with columns: Lab Sample ID, Sample ID, Matrix, Sampled by, Sampled, Sample Note, Analyte, Result, Qualifier, Units, RL, Dil, Method, Prepared, Analyzed, Analyst, Batch. Rows include various analytes like Calcium, Iron, Potassium, Magnesium, Sodium, Aluminum, Antimony, Arsenic, Beryllium, Cadmium, Chromium, Copper, Lead, Manganese, Nickel, Selenium, Silver, Thallium, Zinc, Chloride, Fluoride, Sulfate, Alkalinity, Carbonate Alkalinity, Hydroxide Alkalinity, and Asbestos.

Certificate of Analysis

Lab Sample ID: 5J14070-01 Sample ID: Pristine Hydro Filtration System Matrix: Water

Sampled by: Client


Sampled: 10/13/15 15:00

Sample Note:

Analyte	Result	Qualifier	Units	RL	Dil	Method	Prepared	Analyzed	Analyst	Batch
Total Cations.....	0.52		meq/l	0.038	1	_Various	10/16/15 10:33	10/20/15 13:44	jck	[CALC]
Chlorine Residual, Free.....	ND	*	mg/l	0.050	1	SM 4500ClO2-D	10/14/15 16:35	10/14/15 18:00	lac	W5J0763
Dichloramine.....	ND	*	mg/l	0.050	1	SM 4500ClO2-D	10/14/15 16:35	10/14/15 18:00	lac	W5J0763
Monochloramine.....	ND	*	mg/l	0.050	1	SM 4500ClO2-D	10/14/15 16:35	10/14/15 18:00	lac	W5J0763
Chlorine Residual, Total.....	ND	*	mg/l	0.050	1	SM 4500Cl-G	10/14/15 16:35	10/14/15 18:00	lac	W5J0763
E. coli.....	Absent		N/A	1.0	1	SM 9223B	10/14/15 17:00	10/15/15 11:00	sst	W5J0848
Total Coliform.....	Absent		N/A	1.0	1	SM 9223B	10/14/15 17:00	10/15/15 11:00	sst	W5J0848
Mercury, Total.....	ND		ug/l	0.050	1	EPA 245.1	10/16/15 08:38	10/21/15 16:41	apa	W5J0860
Nitrate as NO3.....	ND		mg/l	0.50	1	EPA 353.2	10/14/15 09:23	10/14/15 17:52	AJW	W5J0718
Nitrite as N.....	ND		ug/l	100	1	EPA 353.2	10/14/15 09:23	10/14/15 20:43	AJW	W5J0718
Perchlorate.....	ND		ug/l	2.0	1	EPA 314.0	10/14/15 17:00	10/14/15 17:35	atl	W5J0750
Total Dissolved Solids.....	52		mg/l	10	1	SM 2540C	10/19/15 09:49	10/19/15 17:00	ajw	W5J0937

Case Narrative:

Authorized Signature



Contact: DRAFT REPORT
(Project Manager)

ELAP # 1132
LACSD # 10143
NELAC #4047-002 ORELAP

The results in this report apply to the samples analyzed in accordance with the chain of custody document. Weck Laboratories certifies that the test results meet all requirements of NELAC unless noted in the Case Narrative. This analytical report must be reproduced in its entirety.

Notes:
The Chain of Custody document is part of the analytical report.
Any remaining sample(s) for testing will be disposed of one month from the final report date unless other arrangements are made in advance.
All results are expressed on wet weight basis unless otherwise specified.

ND = NOT DETECTED at or above the Reporting Limit. If J-value reported, then NOT DETECTED at or above the Method Detection Limit (MDL)
NR = Not Reportable
Sub = Subcontracted analysis, original report enclosed.

An Absence of Total Coliform meets the drinking water standards as established by the State of California Department of Health Services .
The Reporting Limit (RL) is referenced as laboratory's Practical Quantitation Limit (PQL).
For Potable water analysis, the Reporting Limit (RL) is referenced as Detection Limit for reporting purposes (DLRs) defined by EPA.

If sample collected by Weck Laboratories, sampled in accordance to lab SOP MIS002

Flags for Data Qualifiers:

* = The recommended holding time for this analysis is only 15 minutes. The sample was analyzed as soon as it was possible but it was received and analyzed past holding time.

A-01 = Analysis subcontracted to LA Testing South Pasadena, CA ELAP 2283